S.No.	Area	Location
32	Dhasal village.	Krishanangar Colliery, Kenda.
33	Fathepur village & part of .G.T. Road.	Dhemomain Colliery, Sitarampur Area.
34	Haripur village, Raniganj Suri Road.	Haripur Colliery, Kenda Area.
35	Huramdanga village	Jamuria Colliery, Sripur Area.
36	Jamuna Bazar.	Jamuria Colliery, Sripur Area.
37	Janakpur village, Kendua Bazar, Kulti Foundary, Kulti Town.	- Ramnagar Colliery (TJSCO).
38	Kenda village.	Newkenda Colliery, Kenda Area.
39	Kuradih village.	Kuradih Colliery, Satgram Area.
40	Palsbon villape.	Ghanashyam Colliery, Kajora Area.
41	Sanctoria village.	Seetalpur Colliery, Sodepur Area.
42	Santhal Bastee.	Balbsid Colliery, KNT area.
43	Seebpur village.	Sripur Area.
44	Sodepur village.	Poidih Colliery, Sodepur Area.
45	Bastee and part of Village, Ushagram North of G.T. Road, Asansol.	New Ghusick Colliery, Sripur Area.

Proposals f°r setting up of thermal and gas-biased power plants in Gujarat

3313. SHRI VITHALBHAI M. PATEL: Will the Minister of ENERGY be pleased to state:

(a) whether it is a fact that Gujarat Government has submitter a number of proposals 'fo.- the setting up of thermal and gas-based power plants in the State;

(b) if so, how many proposals are pending at present with the Central Government;

\C) how many proposals have been cleared and what are the details thereof; and

(d) liy when the remaining proposals will be cleared by the Central Government? 1005 RS—7

THE MINISTER OF STATE IN THE DEPARTMENT OF POWER IN THE MINISTRY OF ENERGY (SHRI KALPNATH RAI): (a) to (c) Information in respect of the proposals received i_n the Cential Electricity • Authority from the Government of Gujarat regarding thermal and gas-based power projects in the State and the present status thereof is contained in the Statement enclosed, *{See* below.)

(d) The clearance of power projects depends on 'factors such as the tying ^{U}P of fuel and other inputs, the availability of various clearances and of adequate resources ond the *inter se* priority of the projects. The proposed schemes could be considered for clearance after all inputsi have been tied up and requisite clearance have been obtained,

Statement

1. No.	Name of the Scheme	Capacity	Present Status
	*		
a)	*CEA Cleared Schemes*		
	(j) Kutch thermal power station (Lignite-based)	1x70 MW	Investment approval of the Planning Commission is awaited.
	(ii) Gandhar gas-turbine Combined Cycle Plant	600 MW	Techno-economically cleared by the CEA, subject to confirmation of the availability of gas by the Ministry of Petroleum and Natural Gas and approval of transmission scheme by the CEA.
	(HO Utrrn gas-turbine Combined Cycle Plant	135 MW	Techno-economically cleared by the CEA, subject to finalisa-tion and clearance of associated transmission scheme and completion of water supply arrangement by the Gujarat Industrial Develop-rrent Corporation.
(b)	*Schemes Under Examination in CEA*		
	(i) Combined Cycle Joint Captive Power Plant at Baroda (Gujarat Industries Power Co. Ltd.)	135 MW	The scheme has been found to be techno-economically in order subject to confirmation in regard to availability of adequate water; formal clear-ance of the CEA is ytt to be accorded.
	(ii) Narmada Thermal Power Station ~)	2x500 MW	These schemes are under exami-nation in the CEA in consul-tation with other appraisin-agencies and could be consig dered for technc-economi-clearance after all inputc have been tied. up and ths requisite clearances have bee come available.
	(iii) Sikka Thermal Power Station Stage-Ill j	2x210 MW	
	(iv) Pipavav gas-turbine Combined Cvcle *v* Plant in South Saurcshtra	750 MW	
	(v) Ankleshwar gas-turbine Combined ! Cycle, Plant	30 MW	
(c)	*Schemes Not Being Pursued Further in the CEA*		
	(i) Gas based TPS at Mahua	2x210 MW	Fuel availability from the Tapti field was not tied up; scheme is not being pursued further, under intimation to Gujarat Electricity Board.
	(ii) Kandla (Repl; cement)	lx60MW	Since the coa.l availability was not tied up, the proposal is not being pursued further, under intimation to the Guja-rat Electricity Board.
	(iii) Simultaneous Cycle Gas based Plant at		The Gujarat Electricity Board have proposed installation
	(i) Balol	6x5.5 MW	of thermal stations at Balol
	(ii) Kalol	6x5.5 MW	and Kalol in the joint sector for which they are to submit a fresh project report.